



Office of the Regional Fire Officer, Bengaluru North Range,
Karnataka Fire & Emergency Services,
Thanisandra Fire Station Premises, Manyata Embassy
Business Park, Nagawara Ring Road, Bengaluru-560 045.



No. 29: Educational : R F O : B N R : 2025

Date: 24-11-2025

To,
The Administrator,
M/S. Sri Sharada Vidyaniketana English High School,
Nandagokula Layout,
Nagawara, Bengaluru-560077.

Sub:- Issue of Compliance Certificate to M/S. Sri Sharada Vidyaniketana English High School constructed at Nandagokula Layout, Nagawara, Bengaluru-560077.

Ref:- 1. This office Fire Advisory Certificate No. 13: Educational : R F O : B N R:2025
Dated: : 24-10-2025.
2. Your request letter dated: 29-10-2025.

* * * * *

With reference to subject cited (1) above 'Fire Advisory Certificate' was issued to M/S M/S. Sri Sharada Vidyaniketana English High School constructed at Nandagokula Layout, Nagawara, Bengaluru-560077 with a condition to fulfill the recommendations and compliance the same within 3 months in the above building.

In reference cited (2) above The Administrator, M/s Sri Sharada Vidyaniketana English High School has requested the undersigned office to issue compliance certificate. In this regard the District Fire Officer, Thanisandra Fire station has inspected M/s Sri Sharada Vidyaniketana English High School constructed at Nandagokula Layout, Nagawara, Bengaluru-560077 on 10-11-2025 and submitted his report recommending to issue Compliance Certificate for the same.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing "Compliance Certificate" to M/s Sri Sharada Vidyaniketana English High School constructed at Nandagokula Layout, Nagawara, Bengaluru-560077. Subject to proper maintenance of fire fighting systems in good working condition and training of 40% of employees in basic fire fighting at R.A.Mudkur fire and Emergency training academy, Bannerughatta road, Bangalore at an earliest.

This fire safety compliance Certificate is shall remains valid till date 23-10-2026 and it is renewable.

Copy to: District Fire Officer, Thanisandra Fire station.

K. L. H. J.

Secretary

GOWRAMMA EDUCATIONAL TRUST
Nandagokula Layout, Nagawara
Bengaluru - 560 077

[Signature]
Regional Fire Officer
Bangalore North Range
Manyata Tech Park,
Nagawara Ring Road, Bangalore-4!



**Office of the Regional Fire Officer, Bengaluru North Range,
Karnataka Fire & Emergency Services,
Thanisandra Fire Station Premises, Manyata Embassy
Business Park, Nagawara Ring Road, Bengaluru-560 045.**



No. 13: Educational : R F O : B N R : 2025

Date: 24-10-2025

To,
The Administrator,
M/S. Sri Sharada Vidyaniketana English High School,
Nandagokula Layout,
Nagawara, Bengaluru-560077.

Sir,

Sub:- Issue of fire Advisory Certificate for "M/S. Sri Sharada Vidyaniketana English High School constructed at Nandagokula Layout, Nagawara, Bengaluru-560077.

Ref:- Applicants letter dated 10-10-2025.

With reference to the subject cited above, the District Fire Officer, Thanisandra Fire Station has inspected the Educational Building 'M/S. Sri Sharada Vidyaniketana English High School' constructed at Nandagokula Layout, Nagawara, Bengaluru-560077 on 13-10-2025 with respect to fire prevention, fire fighting and evacuation measures to be complied in the above premises and submitted the details as follows:-

A. Details of the building / premises :-

01	Name and Address of the Applicant.	: The Administrator, M/S. Sri Sharada Vidyaniketana English High School, Nandagokula Layout, Nagawara, Bengaluru-560077.
02	Name and Address of the premises.	: M/S. Sri Sharada Vidyaniketana English High School, Nandagokula Layout, Nagawara, Bengaluru-560077 U-Dise Number:29280719808.
03	Name and address of the Building owner	: Sri Subbaraju Nandagokula Layout, Nagawara, Bengaluru-560077
04	Number of buildings	: One Building
05	Number of floors	: Ground & 4 Upper Floors



06	<u>Floor-wise details of occupancy:-</u>	
	Ground floor	: 01 Office, Lobby, Corridor
	1 st floor	: 02 Class rooms, Corridor
	2 nd floor	: 02 Class rooms, Corridor
	3 rd floor	: 02 Class rooms, Corridor
	4 th floor	: Auditorium
07	Total Site area	: 296.96 Sq. Mtrs
08	Height of the building	: 16.90 Mtrs.
08	Built up area	:
	Ground floor	: 246.91 Sq. Mtrs.
	1 st floor	: 246.91 Sq. Mtrs.
	2 nd floor	: 246.91 Sq. Mtrs.
	3 rd floor	: 246.91 Sq. Mtrs.
	4 th floor	: 246.91 Sq. Mtrs.
10	Total built-up area	: 1234.55 Sq. Mtrs
11.	<u>Surrounding properties:-</u>	
	East(Side)	: Residential area.
	West(Side)	: Real Estate building.
	North(Front)	: 8.00 mtrs Road.
	South(Rear)	: Vacant property.
12.	<u>Set-back area available around the building :-</u>	
	East(Side)	: Nil
	West(Side)	: Nil
	North(Front)	: 8.00 mtrs
	South(Rear)	: Nil
Allowed setbacks (open space) should be maintained free from further obstructions / constructions.		



Part-B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)			Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from Nagawara Road Opposite of Eliments Mall 12.00 mtrs Road located on West side of building. The Road is hardened to carry the weight of 45,000 kgs.			Complied
02.	No. of entrances	01 Entry/Exit of 6.00 mtrs has been provided.			Complied
03.	No. of staircases/ lifts available	Nos. of staircases	:	03 Nos	Complied
		Width of staircases	:	One of 1.30 mtrs & 2 each of 1.00 mtr.	
		Width of treads	:	30 cms.	
		Height of risers	:	15 cms.	
		Nos. of riser per flight	:	09-13 Nos.	
		Height of handrails	:	Each of 0.90 mtr.	
		Head room clearance	:	2.40 mtrs.	
05	No of Lifts and capacity No of Patients lift	Nos of lifts	:	01 lift is installed	---
		Capacity of lifts	:	06 Passengers i.e (408 Kg Capacity)	
06.	Fire extinguisher	Provided 04 nos. of ABC type fire Extinguisher each of 6 kg capacity			The following extinguishers, should be provided. One water mist extinguisher of 9 ltrs capacity should be kept near each staircase landing. A) One mechanical foam extinguisher of 9 ltrs capacity & one ABC B) type extinguisher of 6 kgs capacity should be



			provided near diesel generator. C) One CO2 extinguisher of 4.5 kgs capacity should be provided near each electrical panel board & electrical room. One ABC type extinguisher of 6 kgs capacity should be located as to be available within 15 mtrs radius.
07.	Diesel generators.	25 KVA Capacity Generators has been provided to supply alternative power for staircase lighting, corridor lighting, firefighting systems and lifts, etc in the event of failure of electricity supply in the building.	Complied.
08.	First aid Hose reel hose.	One Hose reel hose of 36 mtrs length with drum and 01 no rubber lined delivery hose pipes each of 15 mtrs length with gunmetal branch pipe have been provided inside each hose cabinet near each outlet.	Complied.
09	Public address System	Not Provided	Public address system with 2-way communication system with its control panel at ground floor should be provided.
10	Down comer	Not Provided	One down comer system near the staircase should be provided. The down comer should be of 100 mm internal dia and of G.I.'C' class pipe. From the down comer single headed hydrant outlet at each floor landing should be provided.
12	Manually operated electronic Fire alarm system.	Not Provided	Manually operated electrical fire alarm system should be installed with call boxes located near each staircase landing at each floor. The call




			boxes should be of "break glass' type, where the call is transmitted automatically to the control room when the glass of the system is broken. This system should also be connected to an alternative source of power supply (diesel generator). The call boxes should be so installed that their location can be easily noticed from either direction and should be at a height of one meter from the floor level.
13.	Terrace tank over respective tower terrace.	3000 liters water capacity water tank has been provided	The down comer system should be connected to an overhead tank of 25,000 litres capacity.
14.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	One Booster pump is provided with 450 LPM discharge capacity.	The down comer system should be connected one booster pump capable of delivering 900 litres of water per minute.
15.	Fire Control room	Not Provided	Fire Control room Should be provided at ground floor.
16.	Escape routes	Directions in which the Teachers/Staff/Students have to move in the event of any emergency has been displayed in the corridor on each floor during evacuation.	Complied.
17.	Fire order (fire safety plans)	A notice board indicating the action to be taken by the school staffs/employees in Case of an emergency have been displayed along with Telephone Numbers of Thanisandra Fire Station, 080-22971542 & 101/112 080-22971500/550/600 and telephone numbers of nearest Ambulance Service & Police station.	Complied.



18.	No smoking board.	COPTA Sec-4, direction "No Smoking area smoking here is an offence" board has been written in English & Kannada both languages shall be prominently displayed at inside the entry/exit of each floor.	Complied
19.	Fire Siren	Not imparted	Should be provide Fire Siren in the premises to inform the School Faculty's & Others in case of fire emergency & evacuate the area.
20.	Nominate one Fire Nodal Officer	The Head master of the school is Nominated as a nodal officer	Complied
21.	Fire fighting training	Not Imparted.	At least 40% of teaching & non teaching staff should be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore-560 029 or Regional Training center.
22.	<u>Fire precautionary measures :-</u> A) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory etc. B) Accumulation of combustible waste inside the building and in the premises should be avoided. C) The exit ways shall be always kept clear without any obstruction. D) Liquefied petroleum gas should not be stores in the building. E) The doors shall not be kept locked / latched during working hours and shall be free from obstruction. F) During the class hours the class room doors shall not be locked from inside to out side. As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14 th of every year be conducting Fire Safety drills with co-ordinate Fire Service department.		

As such the Karnataka State Fire and Emergency Services department is issuing 'Fire Advisory Certificate' to the Educational Building "M/S. Sri Sharada Vidyaniketana English High School" situated at Nandagokula Layout, Nagawara, Bengaluru-560077, from Fire prevention, Firefighting and Evacuation point of view subject to the compliance of recommendations mentioned above within 03 months from the date of issue of Fire Advisory Certificate.



Note:

1. This is only the "Fire Advisory certificate" issued by the Fire Department from fire safety view of the low-rise already constructed Building. This shall not be considered as No Objection Certificate for the Building.
2. After completion of all the fire fighting installations as advised in Fire Advisory Certificate, 'Fire Advisory Compliance Certificate' shall be obtained from the Fire and Emergency department.
3. This "Fire Advisory certificate" is valid for a period of one year only from the date of issue.


Regional Fire Officer
Bangalore North Range
Manayata Tech Park,
Nagawara Ring Road, Bangalore-45.

24 $\frac{10}{25}$

Copy to: The District Fire Officer, Thanisandra Fire Station, Bengaluru.